

IMPORTANT NOTICE

READ THIS MANUAL COMPLETELY PRIOR TO BEGINNING THE INSTALLATION OF THE **SUPERLOK** $^{\otimes}$ ROOFING SYSTEM. THE MANUFACTURER DETAILS MUST BE FOLLOWED AS A MINIMUM TO INSURE APPROPRIATE WARRANTIES WILL BE ISSUED.

ALWAYS INSPECT EACH AND EVERY PANEL AND ALL ACCESSORIES BEFORE INSTALLATION. NEVER INSTALL ANY PRODUCT IF ITS QUALITY IS IN QUESTION. NOTIFY MBCI IMMEDIATELY IF ANY PRODUCT IS BELIEVED TO BE OUT OF TOLERANCE, SPECIFICATION OR HAS BEEN DAMAGED DURING SHIPMENT.

IF THERE IS A CONFLICT BETWEEN PROJECT INSTALLATION DRAWINGS PROVIDED OR APPROVED BY THE MANUFACTURER AND DETAILS IN THIS MANUAL, PROJECT INSTALLATION DRAWINGS WILL TAKE PRECEDENCE.

Ice Dam Disclaimer

MBCI designs it's standing seam roofs to meet the load requirements dictated by governing codes and project specifications, including applicable snow loads. However, MBCI expressly disclaims responsibilty for weathertightness or roof point loading issues or other hazards resulting from ice dam situations. Any time ice and snow can melt on the main body of the roof and refreeze at the eave or in the shadow of an adjacent wall, an ice dam situation may develop. In addition to local climate, ice dam formation is affected by many other factors, including but not limited to, roof insulation R value, roof panel color, interior temperature of building, heater location in building, eave overhangs, parapet walls, shading of building roof areas from adjacent trees, parapets, buildings, etc. These factors are design and maintenance issues and are outside the control of MBCI. MBCI specifically disclaims any liability for damage due to ice dam formation, although the following issues should be taken into consideration concerning standing seam roofs installed in freezing climates:

- Always use field seamed panels. These machine-folded seams are more durable when subjected to occasional icing.
- Eliminate "cold" eave overhangs and parapet walls from the building design. Roof overhangs outside the heated
 envelope of the building will tend to be colder than the roof areas over the heated envelope. Simple roof designs
 are preferred. Parapet walls at the eave allow ice and snow to collect due to shading effects and the lower roof
 temperatures caused thereby.
- Make sure the interior of the building is adequately insulated and the heating is properly distributed. Inadequate
 insulation in the roof and/or improper heat distribution causes heat flow though the main body of the roof. On days
 when the temperature is below freezing, this heat gain can cause ice and snow to melt and refreeze at the eave
 where the roof is colder.
- Lay out the building to prevent the eaves and other roof areas from being shaded during the winter. This may mean eliminating adjacent trees or reconsidering roof geometries.
- Consider using self-regulating heating cables at the eaves to mitigate the effects of ice dams.
- On building designs using attics, over-insulate the attic floor and provide adequate ventilation in the attic. This will
 reduce heat transfer through the roof resulting in more consistent roof temperatures between eave and field of roof.
- Increase the degree of diligence with respect to underlayment materials at roof areas prone to icing. This may include valleys, eaves, dormers and roof areas near dormers, parapets and the like where shading may occur.

For more information on this subject, please refer to the MCA's Metal Roof Design For Cold Climates manual.

The engineering data contained herein is for the expressed use of customers and design professionals. Along with this data, it is recommended that the design professional have a copy of the most current version of the North American Specification for the Design of Cold-Formed Steel Structural Members published by the American Iron and Steel Institute to facilitate design. This Specification contains the design criteria for cold-formed steel components. Along with the Specification, the designer should reference the most current building code applicable to the project jobsite in order to determine environmental loads. If further information or guidance regarding cold-formed design practices is desired, please contact the manufacturer

©Copyright NCI Group, Inc. 2016 All Rights Reserved

Descriptions and specifications contained herein were in effect at the time this publication was approved for printing. In a continuing effort to refine and improve products, MBCI reserves the right to discontinue products at any time or change specifications and/or designs without incurring obligation. To ensure you have the latest information available, please inquire or visit our website at www.mbci.com. Application details are for illustration purposes only and may not be appropriate for all environmental conditions, building designs or panel profiles. Projects should be designed to conform to applicable building codes, regulations and accepted industry practices. If there is a conflict between this manual and project erection drawings, the erection drawings will take precedence.





TABLE OF CONTENTS

ROOFING SYSTEM

General Description	
ENGINEERING	
Read This First	SL-5
UL 90 Requirements	
12" Properties/Load Tables	
16" Properties/Load Tables	SL-9 – SL-10
GENERAL INFORMATION	
Product Checklist	SL-11 – SL-20
Panel Orientation	SL-21
Installation Guidelines	
Preparatory Requirements	
Unloading	
Handling/Panel Storage	
Proper Handling, Storage and Maintenance of Painted and Galvalume Plus® Panels	SL-26 – SL-27
INSTALLATION SEQUENCE	
Step 1 — Rake Attachments	
Step 2 — Low System Eave	
Step 2A — High System Eave Step 3 — Thermal Spacer (For High Systems Only)	
Step 4 — First Panel	
Step 5 — Clip Installation	
Step 6 — Endlap	
Step 7 — Ridge	
Step 8 — Subsequent Runs Eave	SL-36
Step 9 — Subsequent Runs Endlap	
Step 10 — Subsequent Runs Ridge	
Step 11 — Last Panel Run	
Step 12 — Seaming Operation	
Step 13 — Outside Closure Installation	SL-43
SPECIAL ERECTION TECHNIQUES	
UL 90 Light Transmitting Panel Installation	
Curb Installation	
Pipe Penetration Installation	SL-63 – SL-64
DETAILS	
Open Framing	CL CE
Fixed Eave With Sculptured Gutter	
Fixed Eave With Box Eave Trim	
Floating Ridge	
Floating Vented Ridge	
Fixed Vented Eave	SL-70
Sculptured Rake	
Sculptured Rake With Cleat	
Parapet Rake	
Floating Sculptured High Side Eave	
Fixed Valley	
Floating Hip	





TABLE OF CONTENTS


Wood Deck	
Field Hemming Panel End	SL-78
Floating Endlap	SL-79
Floating Eave with Box Gutter	SL-80
Floating Eave with Eave Trim with Extended Drip Edge	
Fixed Ridge	
Fixed Vented Ridge	
Box Rake	
Parapet Rake	
Fixed Box High Side Eave	
Parapet Fixed High Side Eave	
Floating Valley	
Fixed Hip	
Rigid Insulation Over Metal Deck	0
Floating Endlap	
Floating Eave With Box Gutter	
Floating Eave With Eave Trim with Extended Drip Edge	
Fixed Ridge	
Fixed Vented Ridge	
Box Rake	SL-95
Parapet Rake	SL-96
Fixed Box High Side Eave	SL-97
Parapet Fixed High Side Eave	SL-98
Floating Valley	SL-99
Fixed Hip	





ROOFING SYSTEM

GENERAL DESCRIPTION



Coverage Width - 16" or 12"

Minimum Slope - 1/2:12

Panel Attachment - Low, High (Fixed or Floating) or Utility (No insulation clearance)

Panel Substrate - Galvalume® (standard)

Gauge - Standard: 24; Optional: 22

Finishes - Smooth Striated (standard)* or Embossed Striated

Coatings - Signature® 200, Signature® 300, Signature® 300 Metallic

PRODUCT SELECTION CHART

	Signature [®] 300 Metallic		Signature® 300		Signature® 200		Galvalume Plus [®]	
PRODUCT	24 Ga.	22 Ga.	24 Ga.	22 Ga.	24 Ga.	22 Ga.	24 Ga.	22 Ga.
SuperLok® HS								
16" Wide	•	•	•		•	-	•	_
12" Wide	-	-	•	-	•	-	•	

Signature is a registered trademark of NCI Group, Inc. Galvalume Plus is a registered trademark of BIEC International.

- Available in any quantity.
- Minimum quantity may be required.

Other colors, finishes, gauges, and materials available; please inquire.

* Striated panels are standard to reduce "oil canning".

CAUTION

Diaphragm capabilities and purlin stability are not provided by manufactures SuperLok[®] roof system. Therefore, other bracing may be required to conform to A.I.S.C. or A.I.S.I. specifications.





ROOFING SYSTEM

ARCHITECT/ENGINEER INFORMATION

- 1. **SuperLok**® is a mechanically seamed roof system. **SuperLok**® panels are available in 12" and 16" widths. Factory applied mastic inside of female leg of panel is standard.
- SuperLok® is a structural roofing panel. This panel can be installed directly over purlins or bar joists. It does not require a solid substructure for support. The SuperLok® roof system has several different UL 90 construction numbers.
- 3. **SuperLok**® is recommended for roof slopes of ½:12 or greater.
- 4. Weathertight and aesthetically pleasing endlaps may be accomplished through the use of swaged and prepunched panels. 12" wide panels are not prepunched for endlaps. The manufacturer provides a prepunched back-up plate at the endlap for weathertightness. Swaged endlaps require the roof erection to proceed from right to left as viewed from the eave looking toward the ridge. Roofs with no endlaps and less than 6:12 may be erected from either direction.
- 5. Heavier gauges, striations and embossing minimize oil canning. Industry standard is a minimum 24 gauge material. Striations are standard to reduce oil canning. Oil canning is not a cause for rejection.
- 6. Substructure must be on an even plane from eave to ridge to avoid panel distortion (1/4" in 20', 3/8" in 40' tolerance).
- 7. All panels require end sealant at eave and valley conditions; however, for illustration purposes, this sealant is not shown on all drawings.
- 8. For proper fastener application, see Product Checklist.
- 9. All perimeter trim dimensions in this manual are based on a wall panel thickness of 1¼" ("PBR" Panel). Any variation from this wall panel thickness may affect the perimeter trim dimensions.
- 10. The information in this manual is believed to be correct and accurate.
- 11. Drawings in this manual utilize the low floating clip. Clips are available in low or high fixed, low or high floating and utility.
- 12. Avoid restricting the thermal expansion and contraction of the **SuperLok**® panels. (ie: Do not attach panel to the substructure at both the eave and ridge.) However, panels must be attached to the substructure at one end to prevent their sliding downslope.
- 13. **SuperLok** panels are not designed to be work platforms. Avoid any unnecessary foot traffic on **SuperLok** panels. If foot traffic is required, protect the roof panels by using soft soled shoes and some type of roof pad, temporary deck, or walkway.
- 14. WARNING: Light transmitting panels are not designed or intended to bear the weight of any person walking, stepping, standing or resting on them. THE MANUFACTURER DISCLAIMS ANY WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, that any person can safely walk, step, stand or rest on or near these light transmitting panels or that they comply with any OSHA regulation.
- 15. A vapor retarder may be necessary to protect roofing components when high interior humidity is a factor. The need for a vapor retarder, as well as the type, placement and location should be determined by an architect or engineer. The following are examples of conditions that may require a vapor retarder: (A) Projects where outside winter temperatures below 40°F are anticipated and where average winter interior relative humidity of 45% or greater is expected. (B) Building usages with high humidity interiors, such as indoor swimming pools, textile manufacturing operations, food, paper or other wet-process industrial plants. (C) Construction elements that may release moisture after the roof is installed, such as interior concrete and masonry, plaster finishes and fuel burning heaters.
- 16. Field cutting of the panels should be avoided where possible. If field cutting is required, the panels must be cut with nibblers, snips, or shears to prevent edge rusting. **Do not cut the panels with abrasive saw blades, grinders, or torches.**

CAUTION

Application and design details are for illustration purposes only, and may not be appropriate for all environmental conditions or building designs. Projects should be engineered to conform to applicable building codes, regulations, and accepted industry practices.





IMPORTANT READ THIS FIRST

CAUTION

The use of any field seaming machine other than that provided by the manufacturer will damage the panels and void all warranties and will void all engineering data.

Low Floating System - With or without %" thermal spacer. See Insulation/Thermal Spacer Selection Chart below.

High Floating System - With %8", 5%" or 1" thermal spacer. See Insulation/Thermal Spacer Selection Chart below.

Thermal calculations should be performed for each project to ensure that the thermal movement of the roof is not greater than the floating clip's capacity. Various densities of blanket insulation may affect the installation and or the appearance of a metal roof system. The installer is responsible for selecting the proper clip and thermal spacer for their conditions.

Inst	llation/Thermal Spacer Selection C	hart		
Insulation Thickness	Low System	High System		
No Insulation	3/8" Thermal Spacer	High System Not Recommended		
3" Insulation	Thermal Spacer Not Recommended	%" Thermal Spacer		
4" Insulation	Thermal Spacer Not Recommended	3∕8" Thermal Spacer		
6" Insulation	Low System Not Recommended	Thermal Spacer Not Recommended		

Warning

As with all standing seam roof systems, sound attenuation (example: blanket insulation) should be installed between the panels and open framing, such as purlins or joists, to prevent "roof rumble" during windy conditions.

Applications over solid deck such as rigid insulation over a metal deck or a wood deck may require additional acoustical consideration to ensure that thermal vibration noises are isolated from the building interior. This is especially important if the bottom of the deck is left open to the interior or in cathedral ceiling applications.

A vapor retarder may be necessary to protect roofing components when high humidity is a factor. The need for a vapor retarder, as well as the type, placement and location should be determined by an architect or engineer. The following are examples of conditions that may require a vapor retarder: (A) a project where outside winter temperatures below 40 degrees F. are anticipated and where average winter interior relative humidity of 45% or greater is expected. (B) building usages with high humidity interiors such as indoor swimming pools, textile manufacturing operations, food, paper or other wet-process industrial plants. (C) Construction elements that may release moisture after the roof is installed, such as interior concrete, masonry or plaster work and fuel burning heaters.

Thermal Spacer Disclaimer

The above thermal spacer chart is intended to be used as a general guideline only. Because of the various densities of insulation currently available, the manufacturer cannot guarantee that this chart will be accurate in all situations. Further, the manufacturer does not specifically require that the roofing contractor use thermal spacers with it's **SuperLok** of system. However, please review the following information:

- · Although the manufacturer does not require a thermal spacer, the architect or building owner may.
- In certain environments, the compression of the fiberglass insulation, without a thermal spacer, may create a thermal break which can cause condensation to form on the purlins/joists.
- On uninsulated buildings, eliminating the thermal spacer: (1) may cause "roof rumble" and (2) you may encounter problems holding panel module.
- When a high clip is used without a thermal spacer: (1) you may encounter problems holding panel module and (2) foot traffic on the panel ribs may result in bent clips.
- Using a low clip with too much insulation or too thick of a thermal spacer: (1) may cause "purlin read" (2) may cause difficulty in properly installing the panel side laps, and (3) you may encounter problems holding panel module.





UNDERWRITERS LABORATORIES APPROVAL **SuperLok**®

Construction Number	Panel Width (In.)	Gauge	Clip Type	Clip Spacing	Substrate	UL-2218 Impact Resistance	UL-263 Fire Rating	UL-580 Rating
90	16"	24 min.	*	5'-0 1/16"	Open Framing	Class 4	Class A	Class 90
176	16"	24 min.	N/A	5'-0 1/4"	Open Framing	Class 4	Class A	Class 90
180	16"	24 min.	**	5'-0 1/4"	Open Framing	Class 4	Class A	Class 90
238B	16"	24 min.	**	2'-6"	Composite System	Class 4	Class A	Class 90
437	16"	24 min.	**	5'-0"	Plywood	Class 4	Class A	Class 90
449	16"	24 min.	*	5'-0"	Open Framing	Class 4	Class A	Class 90
451	16"	24 min.	*	2'-0"	Composite System	Class 4	Class A	Class 90
452	16"	24 min.	*	2'-0"	Composite System	Class 4	Class A	Class 90
487	16"	24 min.	**	4'-0"	Composite System	Class 4	Class A	Class 90

^{*} Fixed or Floating (high or low)

NOTES:

- Tests procedures are in accordance with Underwriters Laboratories Standard UL-580 under "Tests For Uplift Resistance of Roof Assemblies".
- 2. A detailed installation method is available for each Construction Number above and can be found in the UL Roofing Materials and Systems Directory. The panels must be installed in a certain manner to achieve the published results.
- 3. The panel qualifies for a Class A fire rating in compliance with Underwriters Laboratories Standard UL-263 when installed over a non-combustible substrate. A Class C fire rating can be obtained over a combustible deck.
- The panel system qualifies under the following Fire Resistance Design Numbers: P225, P227, P230, P237, P265, P268, P508, P510, P512, P701, P711, P720, P722, P726, P731, P734, P801, P815, and P819.
 Refer to the UL Fire Resistance Directory for specific construction methods and hourly ratings.
- 5. **SuperLok**® panels carry a Class 4 rating under UL-2218 "Test Standard For Impact Resistance".

FACTORY MUTUAL APPROVAL SuperLok®

Panel Width	Gauge	Clip Type	Clip Spacing	Hail Damage Rating	ASTM E108 Fire Rating	FM Windstorm Rating
16	24	Floating	4'-0"	Class 1-SH	Class A	Class 1-90
16	22	Floating	5'-0"	Class 1-SH	Class A	Class 1-105
16	22	Floating	4'-0"	Class 1-SH	Class A	Class 1-135

NOTES:

- 1. Tests procedures are in accordance with Factory Mutual Research Corportion (FMRC) Standard 4471.
- 2. A detailed test report is available for each product above. The panels must be installed in a specific manner to achieve the published results. Contact MBCI for more information.

SuperLok [®] is a registered trademark of NCI Building Systems, L.P. **Galvalume** [®] is a registered trademark of BIEC International, Inc. **Vise-Grip** [®] is a registered trademark of American Tool Companies, Inc.

FLORIDA BUILDING CODE PRODUCT APPROVAL


Double-Lok® Roofing System details and engineering load tables have been examined by the State of Florida and comply with the 2010 Florida Building Code Product Approval Number (FL#11819.4).

^{**} Fixed or Floating (high, low, or utility)





SuperLok® Panel



	SECTION PROPERTIES										
			NEG	ATIVE BENI	DING	POS	SITIVE BEND	ING			
PANEL	Fy	WEIGHT	lxe	Sxe	Maxo	lxe	Sxe	Maxo			
GAUGE	(KSI)	(PSF)	(IN.4/FT.)	(IN.3/FT.)	(KIP-IN.)	(IN.4/FT.)	(IN.3/FT.)	(KIP-IN.)			
24	50	1.47	0.0756	0.0711	2.1307	0.1667	0.1025	3.0693			
22	50	1.83	0.1053	0.1027	3.0751	0.2231	0.1387	4.1551			

NOTES


- 1. All calculations for the properties of SuperLok panels are calculated in accordance with the 2012 edition of the North American Specification For Design Of Cold-Formed Steel Structural Members.
- 2. Ixe is for deflection determination.
- 3. Sxe is for bending.
- 4. Maxo is allowable bending moment.
- 5. All values are for one foot of panel width.

The Engineering data contained herein is for the expressed use of customers and design professionals. Along with this data, it is recommended that the design professional have a copy of the most current version of the North American Specification for the Design of Cold-Formed Steel Structural Members published by the American Iron and Steel Institute to facilitate design. This Specification contains the design criteria for cold-formed steel components. Along with the Specification, the designer should reference the most current building code applicable to the project jobsite in order to determine environmental loads. If further information or guidance regarding cold-formed design practices is desired, please contact the manufacturer.





SuperLok® Panel



ALLOWABLE UNIFORM LOADS IN POUNDS PER SQUARE FOOT

24 Gauge (Fy =	24 Gauge (Fy = 50 KSI)											
SDAN TYPE	LOAD TYPE	SPAN IN FEET										
SPAN TYPE LO	LOAD TIPE	2.5	3.0	3.5	4.0	4.5	5.0	5.5				
SINGLE	LIVE	216.0	180.0	154.3	127.9	101.0	81.8	67.6				
2-SPAN	LIVE	216.0	157.8	116.0	88.8	70.1	56.8	47.0				
3-SPAN	LIVE	216.0	180.0	144.9	111.0	87.7	71.0	58.7				
4-SPAN	LIVE	216.0	180.0	135.3	103.6	81.9	66.3	54.8				

22 Gauge (Fy =	22 Gauge (Fy = 50 KSI)											
SDAN TYPE		SPAN IN FEET										
SPAN TYPE LOA	LOAD TIPE	2.5	3.0	3.5	4.0	4.5	5.0	5.5				
SINGLE	LIVE	313.0	260.8	223.6	173.1	136.8	110.8	91.6				
2-SPAN	LIVE	313.0	227.8	167.4	128.1	101.2	82.0	67.8				
3-SPAN	LIVE	313.0	260.8	209.2	160.2	126.5	102.5	84.7				
4-SPAN	LIVE	313.0	260.8	195.3	149.5	118.2	95.7	79.1				


NOTES:

- 1. THE ABOVE LOADS ARE NOT FOR USE WHEN DESIGNING PANELS TO RESIST WIND UPLIFT.
- 2. Strength calculations based on the 2012 AISI Standard "North American Specification for the Design of Cold-formed Steel Structural Members."
- 3. Allowable loads are applicable for uniform loading and spans without overhangs.
- 4. LIVE load capacities are for those loads that push the panel against its supports. The applicable limit states are flexure, shear, combined shear and flexure, web crippling at end and interior supports, and a deflection limit of L/180 under strength-level loads.
- 5. Panel pullover and Screw pullout capacity must be checked separately using the screws employed for each particular application when utilizing this load chart.
- 6. The use of any field seaming equipment or accessories including but not limited to clips, fasteners, and support plates other than tha provided by the manufacturer may (eave, backup, rake, etc.) damage panels, void all warranties and will void all engineering data.
- 7. This material is subject to change without notice. Please contact MBCI for the most current data.

The Engineering data contained herein is for the expressed use of customers and design professionals. Along with this data, it is recommended that the design professional have a copy of the most current version of the North American Specification for the Design of Cold-Formed Steel Structural Members published by the American Iron and Steel Institute to facilitate design. This Specification contains the design criteria for cold-formed steel components. Along with the Specification, the designer should reference the most current building code applicable to the project jobsite in order to determine environmental loads. If further information or guidance regarding cold-formed design practices is desired, please contact the manufacturer.



SuperLok® Panel



	SECTION PROPERTIES											
			NEG	ATIVE BENI	DING	POS	SITIVE BEND	ING				
PANEL	Fy	WEIGHT	lxe	Sxe	Maxo	lxe	Sxe	Maxo				
GAUGE	(KSI)	(PSF)	(IN.4/FT.)	(IN.3/FT.)	(KIP-IN.)	(IN.4/FT.)	(IN.3/FT.)	(KIP-IN.)				
24	50	1.38	0.0574	0.0538	1.6096	0.1324	0.0779	2.3324				
22	50	1.72	0.0794	0.0776	2.325	0.1779	0.1057	3.1654				

NOTES:


- 1. All calculations for the properties of SuperLok panels are calculated in accordance with the 2012 edition of the North American Specification For Design Of Cold-Formed Steel Structural Members.
- 2. Ixe is for deflection determination.
- 3. Sxe is for bending.
- 4. Maxo is allowable bending moment.
- 5. All values are for one foot of panel width.

The Engineering data contained herein is for the expressed use of customers and design professionals. Along with this data, it is recommended that the design professional have a copy of the most current version of the North American Specification for the Design of Cold-Formed Steel Structural Members published by the American Iron and Steel Institute to facilitate design. This Specification contains the design criteria for cold-formed steel components. Along with the Specification, the designer should reference the most current building code applicable to the project jobsite in order to determine environmental loads. If further information or guidance regarding cold-formed design practices is desired, please contact the manufacturer.





SuperLok® Panel



ALLOWABLE UNIFORM LOADS IN POUNDS PER SQUARE FOOT

24 Gauge (Fy = 5	4 Gauge (Fy = 50 KSI)											
SPAN TYPE	LOAD TYPE	SPAN IN FEET										
SPAN ITPE		2.5	3.0	3.5	4.0	4.5	5.0	5.5				
SINGLE	LIVE	162.0	135.0	115.7	97.2	76.8	62.2	51.4				
2-SPAN	LIVE	162.0	119.2	87.6	67.1	53.0	42.9	35.5				
3-SPAN	LIVE	162.0	135.0	109.5	83.8	66.2	53.7	44.3				
4-SPAN	LIVE	162.0	135.0	102.2	78.3	61.8	50.1	41.4				

2 Gauge (Fy = 50 KSI)											
SPAN TYPE	LOAD TYPE	SPAN IN FEET									
		2.5	3.0	3.5	4.0	4.5	5.0	5.5			
SINGLE	LIVE	233.4	194.5	166.7	131.9	104.2	84.4	69.8			
2-SPAN	LIVE	233.4	172.2	126.5	96.9	76.5	62.0	51.2			
3-SPAN	LIVE	233.4	194.5	158.2	121.1	95.7	77.5	64.0			
4-SPAN	LIVE	233.4	194.5	147.7	113.1	89.3	72.4	59.8			


NOTES:

- 1. THE ABOVE LOADS ARE NOT FOR USE WHEN DESIGNING PANELS TO RESIST WIND UPLIFT.
- 2. Strength calculations based on the 2012 AISI Standard "North American Specification for the Design of Cold-formed Steel Structural Members."
- 3. Allowable loads are applicable for uniform loading and spans without overhangs.
- 4. LIVE load capacities are for those loads that push the panel against its supports. The applicable limit states are flexure, shear, combined shear and flexure, web crippling at end and interior supports, and a deflection limit of L/180 under strength-level loads.
- 5. Panel pullover and Screw pullout capacity must be checked separately using the screws employed for each particular application when utilizing this load chart.
- 6. The use of any field seaming equipment or accessories including but not limited to clips, fasteners, and support plates other than the provided by the manufacturer may (eave, backup, rake, etc.) damage panels, void all warranties and will void all engineering data.
- 7. This material is subject to change without notice. Please contact MBCI for the most current data.

The Engineering data contained herein is for the expressed use of customers and design professionals. Along with this data, it is recommended that the design professional have a copy of the most current version of the *North American Specification for the Design of Cold-Formed Steel Structural Members* published by the American Iron and Steel Institute to facilitate design. This Specification contains the design criteria for cold-formed steel components. Along with the Specification, the designer should reference the most current building code applicable to the project jobsite in order to determine environmental loads. If further information or guidance regarding cold-formed design practices is desired, please contact the manufacturer.



PRODUCT CHECKLIST






PRODUCT CHECKLIST

Eave Plate, Low


- 8'-0" length
- 14 gauge
- Red Oxide

Eave Plate, High

- 8'-0" length
- 14 gauge
- Red Oxide



HW-7600 L




HW-7616 L

Floating Eave Plate, Low


- 8'-0" length
- 14 gauge
- Red Oxide

Floating Eave Plate, High

- 8'-0" length
- 14 gauge
- Red Oxide



HW-7617 🔲




HW-7618 __

Mid-Slope Fixed Plate, Low

- 14 gauge
- Red Oxide


Mid-Slope Fixed Plate, High

- 14 gauge
- Red Oxide



HW-7630 (10'-0" Long) HW-7631 (20'-0" Long)

HW-7632 (6'-0" Long)




HW-7637 (6'-0" Long) HW-7638 (10'-0" Long)

SL-12



PRODUCT CHECKLIST


Valley Support Plate - Low Systems



- Standard Width
- Use Over Purlins/Joists

10'-0" Long P-106


Extended Valley Support Plate - Low Systems



- Extended Width
- Use Over Purlins/Joists

10'-0" Long P-101


Valley Support Plate - High Systems



- Standard Width
- Use Over Purlins/Joists

10'-0" Long P-164


Valley Support Plate - High Systems



- Extended Width
- Use Over Purlins/Joists

10'-0" Long P-162


Valley Support Plate - Low Systems



- Standard Width
- Use Over Rigid Insulation

10'-0" Long P-105


Valley Support Plate - Low Systems



- Extended Width
- Use Over Rigid Insulation

10'-0" Long P-100


Hip Support Plate - High or Low Floating Systems



• Use Over Purlins/Joists

10'-0" Long P-141


Hip Support Plate – Low Floating Systems



• Use Over Solid Substrate

10'-0" Long P-140

Ridge/Hip Support Plate - Low Fixed Systems



• Use with all Substrates

10'-0" Long P-145

Ridge/Hip Support Plate - High Fixed Systems


• Use with all Substrates

10'-0" Long P-155





PRODUCT CHECKLIST




‡ It is the user's responsibility to ensure that the installation and use of all light transmitting panels comply with State, Federal and OSHA regulations and laws, including, but not limited to, guarding all light transmitting panels with screens, fixed standard railings, or other acceptable safety controls that prevent fall-through.

REV 00.01



PRODUCT CHECKLIST

Ridge Flashing




PART NO.	ROOF PITCH	DIM. "A"	NOTE
FL-200	1/2-33/4:12	3½"	For use without ventilator
FL-202	313/16-6:12	41/2"	18" Peak purlin spacing
FL-213	1/2-33/4:12	6½"	For use without ventilator
FL-214	313/16-6:12	7½"	24" Peak purlin spacing

Floating Peak Box



Specify Roof Slope



FL-125 L Length - 2'-1" Girth - 331/4"

• For use with FL-200, FL-202, FL-213, FL-214, FL-300, FL-302, FL-540 or FL-541 Ridge Flashing

FL-126

Length - 2'-6" Girth - 371/4"


• For use with FL-205, FL-207, FL-303, FL-304, FL-543 or FL-544 Ridge Flashing


Ridge Flashing for **Perforated Vent Drip**

Ridge/Hip Flashing - Fixed

PART NO.	ROOF PITCH	DIM. "A"	NOTE	
FL-300	1/2-33/4:12	41/2"	For use with perforated vent drip (FL-254)	
FL-302	313/16-6:12	5½"	18" Peak purlin spacing	
FL-303	1/2-33/4:12	7½"	For use with perforated	
FL-304	313/16-6:12	81/2"	vent drip (FL-254) 24" Peak purlin spacing	

Perforated Vent Drip






24 Gauge Material

FL-254

"Z" Closure





24 Gauge Material

FL-361

· Specify open hem

COLOR


PART NO.	ROOF PITCH	DIM. "A"	NOTE	
FL-209	1/2-33/4:12	6"	For use without vent material 18" Peak purlin spacing For use without vent material 24" Peak purlin spacing	
FL-211	313/16-6:12	7"		
FL-212	All Pitches	11½"		

Ridge End Cap


• Specify Ridge to be used and Roof Slope


FL-201 L

COLOR



Sculptured High Side Eave Trim






PART NO.	ROOF PITCH	DIM. A	
FL-265	1/4-13/4:12	2"	
FL-265B	1 ¹³ / ₁₆ -4:12	311/16"	






PRODUCT CHECKLIST



PART NO.	ROOF PITCH	DIM."A"	GIRTH
FL-248A	1/2-4:12	75/16"	23¾16"
FL-248B	4%16-6:12	715/16"	247/16"

• For use with Sculptured Gutter 10" FL-246




- Use with all Sculptured or Style Gutters
- End Caps will be made to fit gutter ordered
- Specify left or right
- Specify gutter part number


FL-245


FL-117








Sculptured Eave Trim



















PRODUCT CHECKLIST




NOTE: All trim to be 26 gauge material unless noted. Refer to current price book for part numbers and descriptions.





PRODUCT CHECKLIST



FL-705

24 Gauge Material

FL-711

24 Gauge Material



PRODUCT CHECKLIST

Fastener #1B

 Clip to purlin (Up to 4" insulation between panel and purlin)



1/4"-14 x 1 1/4" Self Driller 5/16" Hex Washer Head with no washer

Fastener #142


 Clip to purlin (Over 4" insulation between panel and purlin)



1/4"-14 x 1 1/2" Self Driller 5/16" Hex Washer Head with no washer

Fastener #2B

Endlap over plywood



1/4"-14 x 1" Long Life AB
3/8" Hex Washer Head, with sealing washer

Fastener #5

- Rake support to purlin (Floating System Only)
- Floating eave plate to eave strut



1/4"-14 x 1 1/4" Shoulder Tek® 2 Self Driller 5/16" Hex Washer Head, with no washer

Fastener #1E




- Panel to eave plate or eave strut
- · Rake trim to roof panel
- Standard endlaps
- Panel to valley plate
- Outside closure to panel with back-up plate or support plate

 $\frac{1}{4}$ "-14 x 1 $\frac{1}{4}$ " Long Life Self Driller $\frac{5}{16}$ " Hex Washer Head, with sealing washer

Fastener #2A

 Use in place of Fasteners #1E, #2B and #4 at all strip outs



17 x 1" Long Life AB 5/16" Hex Washer Head, with sealing washer


Fastener #6A

· Clip to joist



12-24 x 1 1/4" Tek® 5 Self Driller 5/16" Hex Washer Head, with no washer

Fastener #4



- Ridge and other flashing to outside closure
- · Gutter to panel
- Gutter to strap
- Trim to trim connections
- Sculptured eave trim to panel

1/4"-14 x 7%" Long Life Lap Tek® Self Driller 5/16" Hex Washer Head, with sealing washer

Fastener #11

- Special application fastener
- For attaching trim to masonary walls



1/4" x 1 1/4" Nail Drive Masonry Anchor





PRODUCT CHECKLIST


Fastener #12A	 Rake angle to purlin Hip and valley support plates to purlins Valley flashing to valley support plate 	Fastener #13A	 Offset cleat to plywood Rake angle to plywood
12 x 1" #2 Phillips/Square Drive	Pancake Head Driller	12 x 1" #2 Phillips/Square Drive	Pancake Type "A"
Fastener #14A	Outside closure to angle on floating hip detail	Fastener #14	Trim to trim connections
			⊒
Stainless Steel Pop Rivet 1/8" dia	ameter x %" grip range	Stainless Steel Pop Rivet 1/8" dia	ameter x ¾6" grip range
Fastener #226	 Dekstrip to Expansion Ridge/Expansion Lap 	Fastener #1	 Eave plate to eave strut Mid-slope fixed plate to purlin
	=		 Rake support to angle (Fixed system only)
3/16" x 9/16" Rivet Cendalum Closed End Rivet		1/4"-14 x 1" Self Driller 5/16" Hex Head, with 5/6" O.D. wa	sher
Fastener #18	 Panel clips to wood deck Outside closure to panel over wood deck 	Fastener #46	Panel endlaps over solid substrate
		1/4"-14 x 5%" Long Life Type B with washer	
14 x 1" Type A 5/16" Hex Washer Head, with 5/8'	O.D. washer	Deck Screw	18 Gauge maximum drilling thickness
Fastener #228	Dekstrip to Expansion Ridge/Expansion Lap		
		Fastener #209 14 x 2"]
10 x ½" Aluminum Grommet Wa	asher	Fastener #210 14 x 3" Fastener #211 14 x 4" Fastener #15D 14 x 6"	

REV 00.01





SuperLok® Panel Orientation




INSTALLATION GUIDELINES

- I. Jobsite Storage and Handling
 - A. Check the shipment against the shipping list.
 - B. Damaged material must be noted on Bill of Lading.
 - C. Panel crates should be handled carefully. A spreader bar of appropriate length is recommended for hoisting.
 - D. Check to see that moisture has not formed inside the bundles during shipment. If moisture is present, panels should be uncrated and wiped dry, then restacked and loosely covered so that air can circulate between the panels.
- II. Application Checklist
 - A. Check substructure for proper alignment and uniformity to avoid panel distortion.
 - B. Periodic check of panel alignment is crucial to proper panel alignment.
 - C. If there is a conflict between this manual and the project erection drawings, the erection drawings will take precedence.

III. LTP Warning

A. WARNING: Light transmitting panels are not designed or intended to bear the weight of any person walking, stepping, standing or resting on them. THE MANUFACTURER DISCLAIMS ANY WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, that any person can safely walk, step, stand or rest on or near these light transmitting panels or that they comply with any OSHA regulation.



SHEETING DIRECTION FOR ROOFS WITH PANEL ENDLAPS

RIGHT TO LEFT ONLY

SHEETING DIRECTION FOR ROOFS WITHOUT PANEL ENDLAPS





PREPARATORY REQUIREMENTS

- 1. For the purpose of this manual, we have assumed that the **SuperLok**® roof will be installed over purlins and an eave gutter will be installed. Please refer to the Design Section of the manuals for details of SuperLok® over other substrates.
- 2. A rake angle or an alternate structural flat surface must be installed on top of the purlins to accept the rake support.
- 3. All primary and secondary framing must be erected, plumbed and squared with bolts tightened according to accepted building practices.
- 4. The substructure (eave to ridge) must be on plane (1/4" in 20' or 3/8" in 40' tolerance).
- 5. It is critical that the purlins or bar joists at the ridge and endlaps be located exactly as detailed and that they are straight from rafter to rafter. Any mislocation or bowing of these members can cause the fasteners at the ridge or endlaps to foul as the panels expand and contract.
- 6. The manufacturer recommends the use of a screw gun with a speed range of 0-2000 RPM to properly install all fasteners referenced in this manual. Tools rated to 4000 RPM should never be used for self drilling fasteners typically supplied with metal roof and wall systems.
- 7. Field cutting of the panels should be avoided where possible. If field cutting is required, the panels must be cut with nibblers, snips, or shears to prevent edge rusting. Do not cut the panels with abrasive saw blades, grinders, or torches.

CAUTION

Avoid restricting the thermal expansion and contraction of the **SuperLok**® panels. (i.e., Do not attach panel to the substructure at either the eave and ridge.)

WARNING: Light transmitting panels are not designed or intended to bear the weight of any person walking, stepping, standing or resting on them. THE MANUFACTURER DISCLAIMS ANY WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, that any person can safely walk, step, stand or rest on or near these light transmitting panels or that they comply with any OSHA regulation.

NOTE


It is the responsibility of the erector to install this roof using safe construction practices that are in compliance with OSHA regulations. The manufacturer is not responsible for the performance of this roof system if it is not installed in accordance with the instructions shown in this manual. Deviations from these instructions and details must be approved in writing by the manufacturer.

CAUTION

Diaphragm capabilities and purlin stability are not provided by the **SuperLok**® roof system. Therefore, other bracing may be required.

REV 00.01






UNLOADING

Upon receiving material, check shipment against shipping list for shortages and damages. The manufacturer will not be responsible for shortages or damages unless they are noted on the shipping list.

Each bundle should be lifted at its center of gravity. Where possible, bundles should remain banded until final placement on roof. If bundles must be opened, they should be retied before lifting.

When lifting bundles with a crane, a spreader bar and nylon straps should be used. **NEVER USE WIRE ROPE SLINGS, THEY WILL DAMAGE THE PANELS.**



When lifting bundles with a forklift, forks must be a minimum of five feet apart. Do not transport open bundles. Drive slowly when crossing rough terrain to prevent panel buckling.


CAUTION

Improper unloading and handling of bundles and crates may cause bodily injury or material damage. The manufacturer is not responsible for bodily injuries or material damages during unloading and storage.






UNLOADING (Continued)



BLOCK AND BAND

This method of bundling is used for orders that are to be picked up by the customer or shipped by common carrier. 2 x 4's are strapped under the bundles to allow access for straps or a forklift. Bundles less than 25' long may be handled by a forklift. The forklift should have at least 5' between forks. Bundles longer than 25' should be lifted utilizing a spreader bar with nylon straps.




FULL CRATE

This method is used on all overseas shipments or by customer's order. Handling requirements are the same as block and band.

REV 00.01






HANDLING/PANEL STORAGE

Standing on one side of the panel, lift it by the seam. If the panel is over 10' long, lift it with two or more people on one side of the panel to prevent buckling.

Do not pick panels up by the ends.

NOTE:

Protective gloves and safety glasses should always be used while handling panels. OSHA safety regulations must be followed at all times.



Store bundled sheets off the ground sufficiently high to allow air circulation beneath bundle and to prevent rising water from entering bundle. Slightly elevate one end of bundle. Prevent rain from entering bundle by covering with tarpaulin, making provision for air circulation between draped edges of tarpaulin and the ground. PROLONGED STORAGE OF SHEETS IN A BUNDLE IS NOT RECOMMENDED. If conditions do not permit immediate erection, extra care should be taken to protect sheets from white rust or water marks.

Check to see that moisture has not formed inside the bundles during shipment. If moisture is present, panels should be uncrated and wiped dry, then restacked and loosely covered so that air can circulate between the panels.





PROPER HANDLING, STORAGE AND MAINTENANCE OF PAINTED AND GALVALUME PLUS® PANELS PANEL HANDLING

- · All panel bundles must be inspected during unloading and carrier advised immediately if damage is noted.
- Never unload or move panel bundles that have been opened without adequately clamping them. Without the banding to hold the bundle stable, panels may shift during unloading or movement, causing the bundle to fall.
- · Never use wire slings to unload or move panel bundles.
- When unloading or moving panel bundles over 20' long, a spreader bar may be required. It is the erector's responsibility to determine the location and number of lift points required to safely unload or move panel bundles.
- When handling individual panels, always wear protective gloves. OSHA safety regulations must be followed at all times.
- When cutting panels, always wear all required safety equipment such as safety glasses and gloves. Cut panels with
 nibblers, shears or snips. Do not use abrasive blade saws as these will melt the Galvalume® coating causing the panel to
 edge rust which will void the Galvalume® and Paint warranties. Drilling fasteners into panels will create metal filings that
 will rust and create an unsightly stain. Metal filings must removed by sweeping or wiping down panels immediately after
 installation to avoid this occurrence.

PANEL STORAGE

- If water is permitted to enter panel bundles, it is necessary to open bundles, separate the panels and dry all surfaces.
- Store bundled panels off the ground sufficiently high to allow air circulation beneath bundle and to prevent rising water from entering bundle. Slightly elevate one end of bundle.
- Prevent rain from entering bundle by covering with tarpaulin, making provision for air circulation between draped edges of tarpaulin and the ground.
- Prolonged storage of panels in a bundle is not recommended. If conditions do not permit immediate erection, extra care should be taken to protect panels from white rust or water marks. If panels have not been erected within three weeks of receipt, the panels should be removed from the bundle for inspection. Condensation may cause damage to panels. The manufacturer's Paint and Galvalume® warranties do not cover damage caused by improper panel storage.

PANEL MAINTENANCE

- Never allow Galvalume[®] panels to come into contact with or water runoff from dissimilar materials such as copper, lead, or
 graphite. These materials will cause galvanic corrosion of the panels and will void the Galvalume[®] warranty. This includes
 treated wood and AC condensate, both of which contain copper compounds. This also applies to painted panels.
- Always use long life fasteners in all exposed fastener applications. Non long life fasteners can rust through the panel at each exposed fastener location. Use of non long life fasteners in exposed applications will void the Galvalume[®] and Paint warranties.
- Panels should be protected against exposure to masonry products, strong acids or bases and solvents. Exposure to these agents may etch or stain Galvalume Plus[®] panels and cause painted panels to blister or peel.
- Never allow anyone to apply any coating or patching material to the panel surface. These products may contain chemicals
 that will adversely affect the Galvalume Plus[®] or paint coating. Also, water may become trapped between the coating
 material and the panel, causing premature corrosion.

If you have any question as to proper methods to use in the handling, storage or maintenance of these panels, call your nearest manufacturer representative.






Never allow anyone to apply any coating or patching material to the panel surface. These products may
contain chemicals that will adversely affect the Galvalume Plus® or paint coating. Also, water may become
trapped between the coating material and the panel, causing premature corrosion.


If you have any question as to proper methods to use in the handling, storage or maintenance of these panels, call your nearest manufacturer representative.

NOTICE

Uniform visual appearance of Galvalume Plus® coated panels cannot be guaranteed. The Galvalume Plus® coating is subject to variances in spangle from coil to coil which may result in a noticeable shade variation in installed panels. The Galvalume Plus® coating is also subject to differential weathering after panel installation. Panels may appear to be different shades due to this weathering characteristic. If uniform visual appearance is required, the manufacturer recommends that our prepainted Signature® 200 or Signature® 300 panels be used in lieu of Galvalume Plus®. Shade variations in panels manufactured from Galvalume Plus® coated material do not diminish the structural integrity of the product. These shade variations should be anticipated and are not a cause for rejection.







RAKE ATTACHMENT

Attach the rake angle to the purlin with the Fastener #12A.

Attach the rake support on top of the rake angle with the proper self-drilling fasteners (See "Rake Support Fastener Requirements" Below) on 2'-0" centers with a fastener in the first and last prepunched slot. The vertical leg is to be installed flush with the steel line.

IT IS IMPORTANT THAT THE RAKE SUPPORT IS INSTALLED STRAIGHT AND SQUARE WITH THE EAVE AS IT CONTROLS THE ALIGNMENT OF THE ROOF SYSTEM.

Install 6" long pieces of double faced tape (not by Manufacturer) on 3'-0" centers to the top of the horizontal leg of the rake support. This will help hold the insulation in place at the rake.

RAKE SUPPORT FASTENER REQUIREMENTS

- Fixed System Fastener #1
- Floating System Fastener #5


CAUTION

(For Floating Systems Only)

It is important that shoulder fasteners are installed through the CENTER of the slotted holes of the rake support to allow for expansion and contraction.

FLOATING SYSTEM


FASTENER #5




RAKE SUPPORT ATTACHMENT









WALL PANEL INSTALLED BEFORE ROOF



WALL PANEL INSTALLED BEFORE OR AFTER ROOF





LOW SYSTEM EAVE

For applications in which the wall panels have already been erected, install box panel cap trim or offset panel cap trim to the eave strut with Fastener #14. Eave trim must be pulled tight to wall panels with Fastener #14 before fastening to eave strut. For applications in which the wall panels have not been erected, use offset panel cap trim. If using panel cap trim, it will space itself for the wall offset panels. Use three Fastener #14 per trim piece.


Install Tri-Bead tape sealer along top of the trim

For vinyl insulation, install double faced tape (not by Manufacturer) along the length of the top leg of the trim. Double faced tape must be upslope from Tri-Bead tape sealer.


Lap trim 2". Apply two beads of urethane sealant between the trim pieces, approximately 1" from the end of the bottom piece. Attach trim laps in flat eave trim with Fastener #14. Attach trim laps on panel cap trim with Fastener #4.








FLAT EAVE TRIM DETAIL (WITHOUT GUTTER)



OFFSET PANEL CAP TRIM DETAIL (WITH GUTTER)



TRIM ENDLAP DETAIL

STEP 2A

HIGH SYSTEM EAVE

Wall Panels Installed Before Roof

Install high eave plates flush with the outside face of the high crowns of the wall panels. Install Fastener #1 in prepunched slots (1'-0" on center) of the eave plate. The first eave plate will butt against the rake support. All of the eave plates may be installed at this time.

Be sure to butt each eave plate end to end without leaving a gap between the plates. Place an 8" length of Triple Bead tape sealer at each butt joint.

Install box panel cap trim to the top of the eave plates. Check to make sure the trim is flat against the wall. Attach the trim to the eave plate and the wall panel with a Fastener #14 at 10'-0" centers.

Lay Tri-Bead tape sealer across the top of the eave trim, flush with the outside edge.

For vinyl back insulation, install double faced tape (not by manufacturer) along the length of the bottom of the eave plate. Double faced tape must be upslope from the Tri-Bead tape sealer.

Wall Panels Installed After Roof

Install offset panel cap trim to the eave strut and wall panel with Fastener #14 at 10'-0" centers. Use three fasteners per trim piece.

Install high eave plates flush with the outside of the offset panel cap trim. Install Fastener # 1 in each prepunched slot (1'-0" on center) of the eave plate. The first eave plate will butt against the rake support. All of the eave plates may be installed at this time

Lay Tri-Bead tape sealer under the eave plate on top of the offset panel cap trim.

Be sure to butt each eave plate end to end without leaving a gap between the plates. Place an 8" length of Triple Bead tape sealer at each butt joint.


Lay Tri-Bead tape sealer across the top of the eave plates, flush with the outside edge. For vinyl back insulation, install double faced tape (not by manufacturer) along the length of the bottom leg of the eave plate.


Lap trim 2". Apply two beads of urethane sealant between the trim pieces, approximately 1" from the end of the bottom piece. Attach trim laps in flat eave trim with Fastener #14. Attach trim laps on panel cap trim with Fastener #4.


*Not by Manufacturer
















THERMAL SPACER (FOR HIGH SYSTEM ONLY)


Position the thermal spacer on top of the insulation over each purlin and against the rake support prior to installing the roof panel.


Using spray adhesive, (not by manufacturer), adhere the thermal spacer to the insulation (First Panel Run Only). The thermal spacer increases the insulation capacity along the purlins.


SUBJECT TO CHANGE WITHOUT NOTICE











FASTENING PATTERN AT EAVE

*Not by Manufacturer



FIRST PANEL

Position the panel so that it overhangs the eave strut by the dimension shown on the building drawings. The upper end of the panel must extend 7" beyond the web of the purlin if the panel covers eave to ridge. If more than one panel is required to cover eave to ridge, one or more endlaps will be required. The upper end of the panel will extend 10" beyond the web of the purlin at endlaps.


NOTE:


If an endlap is required then roof panel must be sheeted right to left as viewed from the eave looking toward the ridge.

Lay the female leg of the panel over the rake support. To prevent wind damage, secure the female leg of the panel to the rake support with Vise Grip[®] Locking C-Clamps or temporary fasteners. Fasteners must go through the rake support. The panel will not be fastened permanently to the rake support until the rake trim is installed.


Attach the panel to the eave strut or eave plate with Fastener #1E. Five fasteners are required at this location.








RIGHT WAY



WRONG WAY



CLIP INSTALLATION

Hook the panel clip onto male leg of panel. Hold end of clip up to keep it engaged onto male leg and rotate the clip base down to completely engage clip onto male leg. Install panel clips at each purlin.

Before fastening clip to purlins, check to ensure that vertical leg of clip is tight to the vertical leg of the panel. Failure to keep this leg tight to the panel leg will affect panel module.

CLIP FASTENER REQUIREMENTS

Two fasteners per clip


Purlins - Fastener #1B - Up to 4" Insulation Fastener #1F - Over 4" Insulation Bar Joists - Fastener #6A

CAUTION


The panel clip has factory applied mastic in the upper lip. This mastic is compressed when the clip is rotated in place. If, for some reason, a clip must be removed, a new clip must be used.









PANEL INSTALLATION SEQUENCE







ENDLAP-PANEL

NOTE:

Step 6 applies only where more than one panel is used in a single slope.

Slide a prepunched back-up plate onto the upslope end of the bottom panel. Make sure the teeth on top of the back-up plate are on top of the panel. Visually check to ensure that the prepunched holes in the back-up plate are aligned with the prepunched holes in the panel. At upslope end of bottom panel, install Tri-Bead tape sealer across entire width of panel. Tape sealer must be centered over prepunched holes in panel. Apply swaged endlap tape sealer to swaged vertical male leg of upper panel. Pigtail portion of tape sealer must lap over vertical leg of panel.

Using an awl to align the prepunched holes, install upper panel by nesting it over the lower panel for 6". Rotate the male leg of the upper panel under the male leg of the bottom panel, then force the female leg of the upper panel down onto the female leg of the bottom panel. Install Fastener #1E in the prepunched holes in the proper sequence. Install clips as outlined in Step 5.


Repeat this endlap procedure as required until ridge is reached.

NOTE:

If you are using 12" SuperLok® panels, they are not prepunched for endlaps. Use Triple Bead Tape Sealant at endlaps with 12" wide panels.









RIDGE

At the ridge, the panel should extend 7" past the web of the peak purlin.

At the ridge install a back-up plate as outlined in Step 6.

Install clips as outlined in Step 5.






PANEL END SEALANT DETAIL AT RIDGE










SuperLok® PANEL SuperLok® PANEL RAKE SUPPORT FASTENER #5 RAKE ANGLE FASTENER #1E FASTENER #12A PANEL END SEALANT DETAIL AT EAVE SUPPORT FASTENER #5 FASTENER #12A FASTENER #12A FASTENER #12A

SUBSEQUENT RUNS EAVE

Apply urethane sealant to the male leg of the first panel directly over the Tri-Bead tape sealer at the eave. This will prevent water infiltration through the end of the panel seam.

Position the next panel with the female leg over the male leg of the previous panel with panel ends flush.



Clamp the panel seam together at both ends. Long panels may require one or more clamps in the middle. This will help hold panel module.

Install fasteners at eave as outlined in Step 4.

Install clips as outlined in Step 5.


Crimp panel seam at all clip locations with hand crimping tool. Panels should be fully seamed with electric seamer as quickly as possible after a section of the roof is completed.

CAUTION

Panel must be crimped at all clip locations as they are installed to provide temporary wind resistance.









SUBSEQUENT RUNS ENDLAP

Install endlap panels as outlined in Step 6.




Install clips as described in Step 5.



Repeat endlap procedures as required until ridge is reached.









SUBSEQUENT RUNS RIDGE

Install back-up plate and clip as outlined in Step 7.









LAST PANEL RUN

Install rake support at the finishing end of the roof as outlined in Step 1.

FINISHING DIMENSION RUN OF 8" TO 14"

Field cut and bend a 2" tall vertical leg on the panels in the last run of roof. The vertical leg must be tight to the rake support angle. Secure the vertical leg to the rake support angle with clamps or temporary fasteners. At the endlap and ridge, a partial back-up plate must be cut.


FINISHING DIMENSION RUN OF LESS THAN 8"

If the width of the last panel run is 8" or less, a second run of rake support angle must be installed for attachment of the vertical leg of the panel. A variable termination trim will be required to seal the gap between the vertical leg of the panel and the rake trim.

The male leg of the panel and the termination trim must be field cut to fit the condition.







SEAMING OPERATION


As panels are installed, hand crimp at each clip location with the hand crimper. Panels should be completely seamed with the electric seamer as soon as possible.


Push locking arm down to lock crimper onto seam. If difficulty is encountered, check to make sure that the hand crimper is properly alighned on seam. **Do not force locking arm.**


Push crimping arm down to crimp panel. Return both the crimping arm and locking arm to the up postion and remove tool from seam.

REV 00.01









SEAMING OPERATION (Continued)

CAUTION

It is critical that the panel seams are crimped and folded as shown before using the electric seamer. Failure to follow these guidlines will result in damaged seams.

To begin seaming with hand tool, set the hand tool on the seam making sure seam is in the **PHASE 1 Action** slot. Align the edge of the hand tool with the end of the panel. Rotate the forming arm under the handle to produce 6" of **PHASE 1** seam. This should be done three times along the seam for a total of 18".

Return to the end of the panel to begin PHASE 2 Action. Set hand tool onto seam making sure seam is in the PHASE 2 Action slot. Align the edge of the hand tool with the edge of the panel. Rotate the forming arm under the handle to produce 6" of finished PHASE 2 seam. This should be done once per rib. The relationship of this 6" of finished seam to the 18" of crimped seam is critical to the proper alignment of the rolls in the electric seamer.


NOTE


All grease zerk fittings on the hand tool should be greased with lithium based grease daily.


The seam is now ready to accept the electric seamer.













SEAMING OPERATION (Continued)

The electric seamer will run in one direction only. To determine the direction of the seamer, stand at the eave and look upslope. If the roof is being installed left to right, the seamer will run upslope. If the roof is being installed right to left, the seamer will run downslope, An orientation plate is on the seamer to assist you in placing the seamer onto the seam properly. When the roof has endlaps, the panels will always be installed right to left. When the roof slope is 6 on 12 or greater, panels must run right to left.

To begin seaming, set seamer on seam with the locking bar up and to the open side of the seam. The rear wheels should be even with the edge of the roof panel. Push the locking bar down to engage the rolls and turn the seamer on.

Stop seamer about one foot from end of panels. Disengage locking bar and remove the electric seamer. Finish seam with hand tool.


CAUTION

- Seamer operation should be closely supervised at all times.
- A safety line should be attached to the seamer.
- Do not entangle the electrical cords in the seamer tooling while it is in operation. This could cause serious injury or death to the operator and severely damage the seamer.
- Electrical cords should be 10-gauge to provide power to the seamer and never be over 200 feet from the electrical source.











OUTSIDE CLOSURE INSTALLATION

Panels must be seamed before closures can be installed. Install Tri-Bead tape sealer across full width of panels, including under panel seams at ridge. Center of tape sealer should be 1 ½" from end of panels.



Field cut the end of the outside closure that fits to the open side of the panel seam. Notch and bend the vertical leg of the closure above the end tab back to the dimple formed into the closure. It is important that the closures fit tight to the panel seams to prevent the need for excess urethane sealant at this location.

Install outside closures by rotating the end cut for the panel seam into place first. Then rotate the other end of the outside closure into place. The vertical leg of the outside closure should be 2" from the upslope end of the panel. Attach the outside closure to the panel with Fastener #1 at each prepunched hole in the closure. Before installing the next outside closure, install a piece of Tri-Bead tape sealer onto the top flange of the outside closure previously installed. This is to prevent water being blown between the outside closures where the top flanges overlap. After all closures are in place, install Tri-Bead tape sealer across the top flange.




Use urethane sealant to fill any voids around the panel seams on the upslope side of the outside closures.





UL 90 LIGHT TRANSMITTING PANEL INSTALLATION




NOTES:

- 1. Maximum width of purlin flange to be 3 1/2".
- Stiffener plate is to be field installed on bottom side of light transmitting panel over mid-purlin.
- 3. Light transmitting panel rivets that obstruct stiffener plate must be drilled out and replaced with Fastener #1E. Minimum two fasteners per side.
- Stiffener plate must be centered exactly over mid-purlin so that thermal movement of the system is not restrained by the
- 5. Endlaps created by the use of light transmitting panels require roof erection to proceed from right to left as viewed from the eave looking toward the ridge.
- 6. WARNING: It is the user's responsibility to ensure that the installation and use of all light transmitting panels comply with State, Federal and OSHA regulations and laws, including, but not limited to, guarding all light transmitting panels with screens, fixed standard railings, or other acceptable safety controls that prevent fall-through.



ROOF CURB INSTALLATION INSTRUCTIONS



- 1. SuperLok® Panel
- 2. Urethane Sealant
- 3. Outside Cap Cell
- 4. Back-up Plate
- 5. Fastener #1E
- 6. Tri-bead Tape Sealer
- 7. Roof Curb Made From Structural Aluminum (Min. .080 Thickness)
- 8. Water Diverter
- Panel Fins (to be cut from an extra panel the length equal to length of the curb).

When ordering curbs, specify one-piece curbs as shown on this page.

MBCI recommends that only one-piece .080 Aluminum (Min.) roof curbs be used with the SuperLok® roof system. The roof curb will be installed under the roof panels on the upslope end and over the panels at the downslope end. To accomplish this, the roof panels must be endlapped at the upslope and downslope end of the curb. This allows both ends of the curb to shed water and places the heavier gauge metal of the curb under the roof panels for better resistance to foot traffic. The exception is at the downslope end where the curb is on top of the roof panels. Since there are endlaps at this area, back-up plates provide support.

Outside cap cells (for bottom) are used to seal the panel to the roof curb. If the curb must be located in a precise location, order the cap cells loose for field installation.


For the purpose of these instructions, a curb with a factory attached cap cell is illustrated. Panels are assumed to be blank and installed right to left.


CAUTION





CURB INSTALLATION FLOATING ROOF CURB SUPPORT GUIDE






- ♦ INDICATES ROOF PANEL SUPPORTS
- ▲ INDICATES CURB BASE SUPPORTS
- * ADDITIONAL UPLIFT SUPPORTS ARE REQUIRED FOR THE ATTACHMENT OF THE CURB UP LIFT PLATES ONLY.

CAUTION





CURB INSTALLATION CURB BASE INSTALLATION #1



NOTES:


- 1. Install all lower roof panels to support the curb base.
- Install back up plates.

CAUTION





CURB INSTALLATION CURB BASE INSTALLATION #2



NOTES:


1. Apply Triple Bead tape sealer (HW-502) on roof panels as shown

CAUTION





CURB INSTALLATION CURB BASE INSTALLATION #3



NOTES:


- 1. For field located Panel Fin Caps, notch Curb Base at all panel Fins.
- 2. Install Curb Base on lower roof panels with a 3" End Lap.

CAUTION





CURB INSTALLATION CURB BASE INSTALLATION #4



NOTES:


1. Attach the Curb Base to the roof panels.

CAUTION





CURB INSTALLATION CAP CELL INSTALLATION




NOTES:

1. Fill Fin cavity of Cap Cell with Urethane Tube Sealant. Apply Triple Bead tape sealer (HW-502) on the bottom of (2) loose the Cap Cell, install over the panel Fins and attach with (6) Fastener #1E.

CAUTION



CURB INSTALLATION CURB PANEL FIN PREPARATION



NOTES:


1. Field cut male and female panel ribs from an extra roof panel supplied by the building manufacturer.

CAUTION





CURB INSTALLATION FEMALE PANEL FIN INSTALLATION



NOTES:


- 1. Install Triple Bead tape sealer (HW-502) to panel #2 Male Fin, and along the edge of the Curb Base.
- 2. Install the Female Panel Rib over the tape sealer and attach with Fastener # 1E at 12" O.C.

CAUTION





CURB INSTALLATION MALE PANEL FIN INSTALLATION



NOTES:


- 1. Notch the male Panel Fin. Apply Triple Bead tape sealer (HW-502) to the top and side of the Male Panel Fin.
- 2. Apply Triple Bead tape sealer on the Curb Base under the male Panel Fin.
- 3. Insert the field cut male Panel Fin on top of the Triple Bead tape sealer.

CAUTION





CURB INSTALLATION CURB BASE INSTALLATION #5




CAUTION





CURB INSTALLATION CURB BASE INSTALLATION #6



NOTES:

1. Apply Triple Bead tape sealer (HW-502) on Curb Base at the up hill end.

CAUTION


It is the user's responsibility to ensure that openings cut into the roof for installation of roof curbs comply with State, Federal and OSHA regulations and laws, including, but not limited to, guarding roof openings with plywood, fixed standard railings, or other acceptable safety controls that prevent fall-through.

REV 00.01





CURB INSTALLATION CURB BASE INSTALLATION #7



NOTES:


1. Apply Triple Bead tape sealer (HW-502) between the Panel Fins on Panels #5 and #6 for water seal.

CAUTION





CURB INSTALLATION CURB BASE INSTALLATION #8



NOTES:

- 1. Install Roof Panels #5, #6, & #7 to the Curb Base on top of the tape sealer with Fastener #1E (5 per panel).
- Install Roof Panel #8.


REV 00.01

CAUTION






CURB INSTALLATION UPLIFT PLATE DETAIL



NOTE: SLOT LOCATION IS DETERMINED BY THE CURB LENGTH, MAXIMUM SPACING IS 12" O.C.




CAUTION





CURB INSTALLATION UPLIFT PLATE FIELD NOTCH




UPLIFT PLATE MUST BE FIELD NOTCHED AROUND THE BUILDING PURLIN TO ALLOW FOR PANEL MOVEMENT.

CAUTION





CURB INSTALLATION DOWN SLOPE CURB BASE END LAP




CAUTION





CURB INSTALLATION UP SLOPE CURB BASE END LAP




CAUTION






PIPE PENETRATION INSTALLATION RECOMMENDED SMALL AND LARGE PIPE PENETRATION INSTALLATION



RECOMMENDED SMALL PIPE PENETRATION INSTALLATION INSTALL PIPE IN CENTER OF PANEL TO ALLOW BASE OF RUBBER ROOF JACK TO LAY FLAT ON PANEL.




RECOMMENDED LARGE PIPE PENETRATION INSTALLATION


THIS METHOD TO BE USED IN ALL CASES WHERE A PIPE PENETRATION INTERSECTS A PANEL RIB OR WHEN THE PIPE IS TOO LARGE AND WILL NOT ALLOW ADEQUATE WATER FLOW DOWN THE PANEL.






PIPE PENETRATION INSTALLATION DECK-TIGHT INSTALLATION













OPEN FRAMING FIXED EAVE WITH SCULPTURED GUTTER











OPEN FRAMING FIXED EAVE WITH SCULPTURED EAVE TRIM











OPEN FRAMING FIXED EAVE WITH BOX EAVE TRIM








OPEN FRAMING FLOATING RIDGE








OPEN FRAMING FLOATING VENTED RIDGE








OPEN FRAMING FIXED VENTED EAVE











OPEN FRAMING SCULPTURED RAKE







OPEN FRAMING SCULPTURED RAKE WITH CLEAT








SuperLok[®]


OPEN FRAMING PARAPET RAKE








OPEN FRAMING FLOATING SCULPTURED HIGH SIDE EAVE











OPEN FRAMING PARAPET FLOATING HIGH SIDE EAVE








OPEN FRAMING FIXED VALLEY











OPEN FRAMING FLOATING HIP








FIELD HEMMING PANEL END








WOOD DECK FLOATING ENDLAP







WOOD DECK FLOATING EAVE WITH BOX GUTTER




NOTE: DO NOT USE THIS DETAIL ON ROOF SLOPES LESS THAN 3:12





WOOD DECK FLOATING EAVE WITH EAVE TRIM WITH EXTENDED DRIP EDGE




NOTE: DO NOT USE THIS DETAIL ON ROOF SLOPES LESS THAN 3:12






WOOD DECK FIXED RIDGE








WOOD DECK FIXED VENTED RIDGE








WOOD DECK BOX RAKE








WOOD DECK PARAPET RAKE








WOOD DECK FIXED BOX HIGH SIDE EAVE




HIGH EAVE SEALANT DETAIL








WOOD DECK PARAPET FIXED HIGH SIDE EAVE









WOOD DECK FLOATING VALLEY








NOTE: DO NOT USE THIS DETAIL ON ROOF SLOPES LESS THAN 3:12






WOOD DECK FIXED HIP








RIGID INSULATION OVER METAL DECK FLOATING ENDLAP







RIGID INSULATION OVER METAL DECK FLOATING EAVE WITH BOX GUTTER




NOTE: DO NOT USE THIS DETAIL ON ROOF SLOPES LESS THAN 3:12





RIGID INSULATION OVER METAL DECK FLOATING EAVE WITH EAVE TRIM WITH EXTENDED DRIP EDGE




NOTE: DO NOT USE THIS DETAIL ON ROOF SLOPES LESS THAN 3:12






RIGID INSULATION OVER METAL DECK FIXED RIDGE








RIGID INSULATION OVER METAL DECK **FIXED VENTED RIDGE**








RIGID INSULATION OVER METAL DECK BOX RAKE








RIGID INSULATION OVER METAL DECK PARAPET RAKE








RIGID INSULATION OVER METAL DECK FIXED BOX HIGH SIDE EAVE




HIGH EAVE SEALANT DETAIL







RIGID INSULATION OVER METAL DECK PARAPET FIXED HIGH SIDE EAVE




REV 00.01





RIGID INSULATION OVER METAL DECK FLOATING VALLEY




NOTE: DO NOT USE THIS DETAIL ON ROOF SLOPES LESS THAN 3:12





RIGID INSULATION OVER METAL DECK FIXED HIP







NOTES



For the most current information available, visit our Web site at www.mbci.com

Houston, TX 14031 West Hardy P.O. Box 38217 Houston, TX 77238 281-407-6915

Lubbock, TX 5711 East FM-40 P.O. Box 10133 Lubbock, TX 79408 806-224-2724

Salt Lake City, UT 1155 West 2300 North P.O. Box 16027 Salt Lake City, UT 84116 385-715-2952 Adel, GA 1601 Rogers Road P.O. Box 1107 Adel, GA 31620 888-514-6062

Memphis, TN 300 Highway 51 North P.O. Box 366 Hernando, MS 38632 662-298-2337

San Antonio, TX 8677 I-10 East P.O. Box 69 Converse, TX 78109 210-888-9768 Atlanta, GA 2280 Monier Avenue P.O. Box 44729 Atlanta, GA 30336 678-337-1619

Oklahoma City, OK 7000 S. Eastern Avenue P.O. Box 95998 Oklahoma City, OK 73149 405-492-6968 Atwater, CA 550 Industry Way P.O. Box 793 Atwater, CA 95301 209-445-3891

Omaha, NE 1011 Ellison Avenue Omaha, NE 68110 402-983-8006 Ennis TX 1804 Jack McKay Blvd. P.O. Box 1210 Ennis, TX 75120 469-256-8255

Phoenix, AZ 660 South 91st Avenue P.O. Box 739 Tolleson, AZ 85353 480-630-3022 Indianapolis, IN 1780 McCall Drive P.O. Box 657 Shelbyville, IN 46176 317-364-4329

Rome, NY 6168 State Route 233 P.O. Box 4141 Rome, NY 13442 315-371-4330

